



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 240102 - E189179

ISSUE DATE: January 24, 2002

Page 1 of 1

Issued to: ESA Elettronica S.p.A.
Via Padre Masciadri, 4/A
I-22066 Mariano Comense - Como Italia

Report Reference: E189179, December 06, 2001

This is to Certify that representative samples of: Miscellaneous Apparatus, Operator Panel Display (Universal Operator Terminals), VT Series

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508 - Industrial Control Equipment
CSA C22.2 No. 14-M95 - Industrial Control Equipment

Additional Information: Electrical Ratings:
Input: 24 V dc - Powered by Class 2 or Low Voltage Limited Current
Operating Temperature: 50°C all models except model VT 585W and VT 330 WAPM, provided with STN Display; 45°C model VT 585W (STN) and VT 330 WAPM (STN)
Environmental Ratings: Type 12 Front Panel Display

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers; the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer:
Giovanni Verdecy
Giovanni Verdecy - Project Engineer
UL International Italia S.r.l

Review Engineer:
Tim Lueck
Tim Lueck - Project Engineer
UL International Italia S.r.l

Pursuant to the Corporate Services Agreement between UL International Italia Srl and Underwriters Laboratories Inc. ("UL"), UL hereby accepts and issues this Certificate of Compliance.